



IEC 61850 Certificate Level A¹

No. 30620025-Consulting 2006-0298

Issued to:
GE MULTILIN
Avda. Pinoa 10
48170 Zamudio
Spain

For the product:
F650 Bay Controller
Hardware 1
Firmware version 3.06 boot 4.0



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1 Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol and model implementation conformance statements: "PICS for 650 family of relays", v1_5 and "MICS for 650 family", rev1.2 and technical issue (TICS) and extra information for testing (PIXIT): "TICS for 650 family of relays", v1_4 and "PIXIT for 650 family of relays", v1_8".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures):

1 Basic Exchange (21/23)	12a Direct Control (4/11)
2 Data Sets (2/5)	13 Time Synchronization (4/4)
5 Unbuffered Reports (12/13)	14 File transfer (3/6)
6 Buffered Reports (14/15)	

This Certificate includes a summary of the test results as carried out at KEMA Arnhem, the Netherlands with UniCAsim 61850 version 2.13.04 test system running test suite "61850 Conformance Test v2.13.07", UniCA 61850 analyzer version 4.13. The test is based on the UCA International Users Group Device Test Procedures version 1.1. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30620025-Consulting 2006-0299 will prevail.

The test have been carried out on one single specimen of the products as referred above and submitted to KEMA by GE Multilin. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, April 28, 2006

S.J.L.M. Janssen
Managing Director KEMA Consulting

R. Schimmel
Certification Manager

1) Level A – Independent Test Lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail

KEMA Nederland B.V.

Utrechtseweg 310, 6812 AR Arnhem; P.O. Box 9035, 6800 ET Arnhem, The Netherlands.
Telephone + 31 26 356 6142, Telefax + 31 26 515 456, Email sales@kema.com

Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 1.1

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN1f, SrvN2, SrvN3
2: Data Sets	Dset1, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7 RpN1, RpN2, RpN3, RpN4	Rp5, RpN5, RpN6
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9 BrN1, BrN2, BrN3, BrN4, BrN5	Br5, BrN6
12a Direct control	CtIN3, CtIN8 DOns1, DOns3	
13 Time sync	Tm1, Tm2, TmN1	TmN2
14 File transfer	Ft1, Ft2ab, FtN1ab	



Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail

KEMA Nederland B.V.

Utrechtseweg 310, 6812 AR Arnhem; P.O. Box 9035, 6800 ET Arnhem, The Netherlands.
Telephone + 31 26 356 6142, Telefax + 31 26 515 456, Email sales@kema.com