

IEC 61850 Certificate Level A¹

No. 30520015-Consulting 07-0888

Issued to:
ZIV P+C
Parque Tecnológico, 210
48170 Zamudio
Spain

For the product:
#IRV-A
Type: 7IRV-A3N-220400VB
OS version 2.0
Application version 3.13

Issued by:



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1 Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "PICS of the IEC 61850 communication interface in #IRV-A, revision 3", "MICS of the IEC 61850 communication interface in #IRV-A, revision 6", "IEC 61850 Tissues Conformance Statement" and extra information for testing (PIXIT) "PIXIT of the IEC 61850 communication interface in #IRV-A, revision 6".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures):

1 Basic Exchange (20/23)	9ab Generic Object Oriented Substation Events (14/20)
2 Data Sets (2/5)	12a Direct Control (5/11)
5 Unbuffered Reports (9/13)	12c Enhanced Direct Control (7/11)
6 Buffered Reports (12/15)	13 Time Synchronization (3/4)


This Certificate includes a summary of the test results as carried out at ZIV P+C, Spain, with UniCAsim 61850 version 2.14.01 test system running test suite "61850 Conformance Test v2.14.04", UniCA 61850 analyzer version 4.15.00. The test is based on the UCA International Users Group Device Test Procedures version 1.1. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30520015-Consulting 07-0749 will prevail.

The tests have been carried out on one single specimen of the products as referred above and submitted to KEMA by ZIV P+C. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, April 3, 2007



S.J.L.M. Janssen
Managing Director KEMA Consulting



E.F. Melenhorst
Senior Test Engineer

1) Level A – Independent Test Lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail

KEMA Nederland B.V.

Utrechtseweg 310, 6812 AR Arnhem; P.O. Box 9035, 6800 ET Arnhem, The Netherlands.
Telephone + 31 26 356 6142, Telefax + 31 26 515 456, Email sales@kema.com

Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 1.1:

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5, Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN2, SrvN3, SrvN4	Srv6, Srv7, Srv8, SrvN1e
2: Data Sets	Dset1, DsetN1ae	
5: Unbuffered Reporting	Rp1, Rp2, Rp4, RpN1, RpN2, RpN3, RpN4	Rp5, RpN6
6. Buffered Reporting	Br1, Br2, Br4, Br8, Br9, BrN1, BrN2, BrN3, BrN4, BrN5	Br5, BrN6
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1
9b: GOOSE subscribe	Gos1, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a Direct control	CtlN3, CtlN8, DOs1	Ctl2, Ctl7
12c Enhanced Direct control	CtlN3, CtlN8, DOes2, DOes5	Ctl2, Ctl7, CtlN6
13 Time sync	Tm1, Tm2, TmN1	



Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail

KEMA Nederland B.V.

Utrechtseweg 310, 6812 AR Arnhem; P.O. Box 9035, 6800 ET Arnhem, The Netherlands.
Telephone +31 26 356 6142, Telefax +31 26 515 456, Email sales@kema.com