

IEC 61850 Certificate Level A¹

Page 1/2

No. 30710144-Consulting 08-0115

For the product: REF615 Feeder Protection Relay Version: V1.0.1



Issued to:



The product has not shown to be non-conforming to:

IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: IEC 61850 Conformance Statement for RE_615, 1MRS756465 B", "IEC 61850 Model Implementation Conformance Statement (MICS) for RE_615, 1MRS756467 A", "IEC 61850 Tissues Conformance Statement for RE_615, 1MRS756466 B" and product's extra information for testing: "IEC 61850 Protocol Implementation extra Information for Testing (PIXIT) for RE_615, 1MRS756464 B".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v1.1):

2Data Sets (2/5)9bGOOSI4+Setting Group Definition (10/10)12aDirect (10/10)5Unbuffered Reporting (10/13)12dEnhand6Buffered Reporting (13/15)13Time S	E Publish (6/11) E Subscribe (9/9) Control (4/11) ced SBO Control (9/17) Synchronization (3/4) ansfer (5/6)
---	--

This Certificate includes a summary of the test results as carried out at KEMA in The Netherlands with UniCAsim 61850 version 3.16.00 with test suite 3.16.06 and UniCA 61850 analyzer 4.16.00. The test is based on the UCA International Users Group Device Test Procedures version 1.1. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 30710144-Consuling 08-0114 will prevail.

The test have been carried out on one single specimen of the products as referred above and submitted to KEMA by ABB. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, 28 January 2008

S.J.L.M. Janssen Managing Director KEMA Consulting R. Shind

Richard Schimmel Certification Manager

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 1.1

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3,	Srv6, Srv7, Srv8,
	AssN4, AssN5	SrvN1e, SrvN2, SrvN3
	Srv1, Srv2, Srv3, Srv4, Srv5,	
	SrvN1abcd, SrvN4	
2: Data Sets	Dset1, DsetN1ae	
4+: Setting Group	Sg1, Sg2, Sg3, Sg4, Sg5	
Definition	SgN1, SgN2, SgN3, SgN4, SgN5	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7	Rp5
	RpN1, RpN2, RpN3, RpN4	
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9	Br5
	BrN1, BrN2, BrN3, BrN4, BrN5	
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, Gop6
9b: GOOSE subscribe	Gos1, Gos2, Gos3, GosN1, GosN2,	
	GosN3, GosN4, GosN5, GosN6	
12a: Direct control	CltN3, CtlN8	
	DOns1, DOns3	
12d: Enhanced SBO	Ctl3, CltN1, CltN2, CltN3, CltN4,	
control	CtIN9	
	SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2, TmN1	
14: File transfer	Ft1, Ft2ab, FtN1ab	FtN1c, Ft2c

Page 2/2