



# IEC 61850 Certificate Level A<sup>1</sup>

International Usersgroup

No. 30820234-Consulting 09-0762

Issued to:  
P&B Engineering  
Belle Vue Works  
Boundary Street  
Manchester  
M12 5NG  
UK

For the product:  
P&B SuperVision Series  
FeederVision FVD  
Feeder Protection Relay  
Firmware V2.022

Issued by:



The product has not shown to be non-conforming to:  
**IEC 61850-6, 7-1, 7-2, 7-3, 7-4 and 8-1**  
Communication networks and systems in substations

The conformance test has been performed according to IEC 61850-10 with product's protocol, model and technical issue implementation conformance statements: "IEC 61850 Protocol Implementation Conformance Statement(PICS) for P&B SuperVision Series FeederVision FVD relays Version 4.0", "IEC 61850 Model Implementation Conformance Statement(MICS) for P&B SuperVision Series FeederVision FVD relays Version 4.0", "IEC 61850 Tissues Conformance Statement (TICS) for P&B SuperVision Series FeederVision FVD relays Version 4.0" and product's extra information for testing: "IEC 61850 Protocol Implementation eXtra Information for Testing (PIXIT) for P&B SuperVision FeederVision FVD relays Version 4.0".

The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases as defined in the UCA International Users Group Device Test procedures v2.2):

1 Basic Exchange (20/24)	12a Direct Control (4/12)
2+ Data Set Definition (26/29)	12b SBO Control (6/16)
5 Unbuffered Reporting (13/18)	12c Enhanced Direct Control (4/13)
6 Buffered Reporting (16/20)	12d Enhanced SBO Control (9/20)
9a GOOSE Publish (7/11)	13 Time Synchronization (3/5)
9b GOOSE Subscribe (9/10)	14 File Transfer (6/7)

This Certificate includes a summary of the test results as carried out at KEMA in Arnhem, The Netherlands with UniCasim 61850 version 3.18.00 with test suite 3.18.00, UniCA 61850 analyzer 4.18.01 and UniCasim GOOSE 2.18.01. The test is based on the UCA International Users Group Device Test Procedures version 2.2. This document has been issued for information purposes only, and the original paper copy of the KEMA report: No. 09-0763 will prevail.

The test has been carried out on one single specimen of the products as referred above and submitted to KEMA by P&B Engineering. The manufacturer's production process has not been assessed. This Certificate does not imply that KEMA has certified or approved any product other than the specimen tested.

Arnhem, 16 April 2009

  
W. Strabbing  
Manager, Intelligent Networks and Communication

  
Test Engineer

1 Level A - Independent Test lab with certified ISO 9000 or ISO 17025 Quality System

Copyright © KEMA Nederland B.V., Arnhem, the Netherlands. All rights reserved. Please note that any electronic version of this KEMA certificate is provided to KEMA's customer for convenience purposes only. It is prohibited to update or change it in any manner whatsoever, including but not limited to dividing it into parts. In case of a conflict between the electronic version and the original version, the original paper version issued by KEMA will prevail.



Applicable Test Procedures from the UCA International Users Group Device Test Procedures version 2.2

Conformance Block	Mandatory	Conditional
1: Basic Exchange	Ass1, Ass2, Ass3, AssN2, AssN3, AssN4, AssN5 Srv1, Srv2, Srv3, Srv4, Srv5, SrvN1abcd, SrvN4	Srv6, Srv7, Srv8, SrvN1e, SrvN2, SrvN3
2+: Data Set Definition	Dset1, Dset10a, DsetN1ae Dset2, (Dset3), Dset4, (Dset5), (Dset6), Dset7, Dset8, (Dset9) DsetN1cd, DsetN2, (DsetN3), DsetN4, (DsetN5), DsetN6, (DsetN7), DsetN8, (DsetN9), DsetN10a, (DsetN11), DsetN12, DsetN13, (DsetN14), DsetN15	
5: Unbuffered Reporting	Rp1, Rp2, Rp3, Rp4, Rp7, RpN1, RpN2, RpN3, RpN4	Rp5, Rp6, Rp9, RpN5
6: Buffered Reporting	Br1, Br2, Br3, Br4, Br7, Br8, Br9, Br12, BrN1, BrN2, BrN3, BrN4, BrN5	Br5, Br6, Br11
9a: GOOSE publish	Gop2, Gop3, Gop4, Gop7	Gop1, Gop6, GopN1
9b: GOOSE subscribe	Gos1, Gos2, Gos3, GosN1, GosN2, GosN3, GosN4, GosN5, GosN6	
12a: Direct control	CtlN3, CtlN8 DOns1, DOns3	
12b: SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, SBOs2	
12c: Enhanced Direct Control	CtlN3, CtlN8, DOes2, DOes5	
12d: Enhanced SBO control	Ctl3, CtlN1, CtlN2, CtlN3, CtlN4, CtlN9 SBOes1, SBOes2, SBOes3	
13: Time sync	Tm1, Tm2, TmN1	
14: File transfer	Ft1, Ft2ab, Ft4, FtN1ab	Ft2c, FtN1c

Note: Dset3, Dset5, Dset6, Dset9, DsetN3, DsetN5, DsetN7, DsetN9, DsetN11, DsetN14 These testcases have not been performed since the DUT does not support non-persistent datasets.